



Aalborg Universitet

AALBORG UNIVERSITY
DENMARK

Individual Module Maximum Power Point Tracking for a Thermoelectric Generator Systems

Vadstrup, Casper; Chen, Min; Schaltz, Erik

Publication date:
2012

Document Version
Accepted author manuscript, peer reviewed version

[Link to publication from Aalborg University](#)

Citation for published version (APA):
Vadstrup, C., Chen, M., & Schaltz, E. (2012). *Individual Module Maximum Power Point Tracking for a Thermoelectric Generator Systems*. Poster presented at The 31st International & 10th European Conference on Thermoelectrics, Aalborg, Denmark.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

Individual Module Maximum Power Point Tracking for Thermoelectric Generator Systems

Casper Vadstrup (cvdst08@student.aau.dk), Min Chen (mch@et.aau.dk), Erik Scholtz (esc@et.aau.dk)


Department of Energy Technology, Aalborg University, Denmark

1 Introduction

Due to the varying nature of the output voltage of Thermo Electric Generator (TEG) systems a power converter is often inserted between the TEG system and the load. The power converter is operated by a Maximum Power Point Tracker (MPPT) which insures that the TEG system produces the maximum power. However, if the conditions, e.g. temperature, health, age, etc., of one or more modules are different from the other modules the full potential of the system is not reached as each module will have its own operation point of maximum power. The MPPT will therefore only find the best compromise of all modules. In order to increase the power production of the TEG system all the modules should therefore be operated at their individual Maximum Power Point (MPP).

2 TEG Modeling



The TEG modules can be modeled as Thévenin or Norton circuits. V_i [V] is the inner voltage source, I_i [A] is the inner current source and R_i [Ω] is the inner resistance.



The inner voltage source, current source and resistance depends all on the temperature difference ΔT [$^{\circ}\text{C}$] of the module.



3 Maximum Power Point

The MPP of each module depends on the temperature difference. Therefore, in order to increase the system output power each module should be operated at its MPP.



4 Implementation

Four Non-Inverting Buck-Boost converters have been built. Two TEG modules are connected in series at each converter input.



5 Conclusion

By operating each module in a TEG system on its MPP the output power can be increased by up to 9.5 % in compare to when MPPT only is applied at stack level.